

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.SZP/HD/T4-89/2019
2310

Date :- 21/11/2019

It is certified that an inspection team headed by *Dr.V.D.Nandrekar, Add.District* from *Health Officer, Zilla Parishad Sindhudurg*, inspected the - *Shri. Yashvantrao Bhonsale International School Charathe Vazarwadi, Tal - Sawantwadi* on *Dt.6/11/2019* *Water Sample Report* found that the *Shri. Yashvantrao Bhonsale International School Charathe Vazarwadi, Tal - Sawantwadi* has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.



W. D. Nandrekar
(विजय द. नंद्रेकर)
अति. जिल्हा आरोग्य अधिकारी
जिल्हा परिषद, सिंधुदुर्ग.

To
Secretary,
Shri.Yashvantrao Bhonsale International School
Charathe Vazarwadi, Tal - Sawantwadi

\\E:\NOV13-PC\office\11032019\11032019\CERTIFICATE\APPENDIX - VIII.docx

[Signature]
SECRETARY
Shri Yashwantrao Bhonsale
Education Society

[Signature]
PRINCIPAL
YASHWANTRAO BHONSALE
INTERNATIONAL SCHOOL



Senior Geologist
Ground Water Survey And Development Agency, Sindhudurg
Water Sample Chemical Testing Report

E - Mail : sdsiwadi@gmail.com

Phone No. (02363) 273443

Sender Name : Yashwantrao Bhosale Education Society,Charathe

Taluka : Sawantwadi

Dist :Sindhudurg

Reference Letter No. & Date : 06.11.2019

Lab Ref No : SDLS/IC863/19

Sr. No.	Name of Block	Name of Panchayat	Name of Habitation	Location / UID	Type of Source	Sample Received Date	Sample Testing Date	Temp	Color	Odor	Tur (NTU)	pH	EC	TDS (mg/L)	Alkalinity (mg/L)	Chloride (mg/L)	Fluoride (mg/L)	Nitrate (mg/L)	Total Hardness (mg/L)	Iron (mg/L)	Calcium (mg/L)	Remark
1	Sawantwadi	Charathe	Vazariwadi	Infront of School	Openwell	06.11.2019	06.11.2019	29	Colourless	Odourless	0.7	7.0	110	72	14	6	0.2	1	18	0.1	3	Fit

S.D.Siwadi
Senior Geologist
 G.S.D.A. Sindhudurg

Indian Standard IS 10500 : 2012

Acceptable Limit - pH : 6.5 - 8.5, Turbidity 1, TDS 500, Calcium 75, Chloride 250, Fluoride 1.0, Iron 1, Nitrate 45, Sulphate 200, Alkalinity 200, T. Hardness 200
 Permissible Limit - pH : 6.5 - 8.5, Turbidity 5, TDS 2000, Calcium 200, Chloride 1000, Fluoride 1.5, Iron & Nitrate - No relaxation, Sulphate 400, Alkalinity 600, T. Hardness 600

S.D.Siwadi

SECRETARY
 Shri Yashwantrao Bhosale
 Education Society

S.D.Siwadi

PRINCIPAL
YASHWANTRAO BHONSALE
INTERNATIONAL SCHOOL

Format - 4

Senior Geologist Ground Water Survey And Development Agency, Sindhudurg
Sub Divisional Laboratory Sawantwadi

Bacteriological Water Sample Testing Report

E-Mail : sdiswadi@gmail.com

Telephone :273443

Sender Name : Shri. Yashwantrao Bhosale Education Society, Charathe, GP : Charathe , Taluka : Sawantwadi, Dist : Sindhudurg

Sender Ref. Letter No. & Date : - , Date - 06.11.2019

Outward No & Date : GSDA/SWD/BACT/279. DATE : 13.11.2019

Sr. No.	Grampanchayat Name	Habitation Name	Source Location	Source Type	Source Code No.	Sample Collection Date & Time	Sample Analysis Date	Residual Chlorine	E-Coli	Total Coliform	Fit / Unfit for Drinking	Remark
1	2	3	4	5	6	7	8	9	10	11	12	13
1	CHARATHE	VAZARWADI	SHALESAMORIL VIHIR	OPEN WELL	-	06.11.2019	06.11.2019	0.2	0	0	Fit	


Senior Geologist
GSDA Sindhudurg



SECRETARY
Shri Yashwantrao Bhosale
Education Society



PRINCIPAL
YASHWANTRAO BHONSALE
INTERNATIONAL SCHOOL

YASHWANTRAO BHONSALE
INTERNATIONAL SCHOOL
Sawantwadi, Dist. Sindhudurg
Pin - 415002